

**DECLARATION OF CONFORMITY  
TO THE GERMAN RULES FOR GRID CODE STANDARD**

With respect to synchronous alternators designed to comply with the following standard:

- ✓ VDE-AR-N 4105:2018-11 - Generators connected to the low-voltage distribution network - Technical requirements for the connection to and parallel operation with low-voltage distribution networks.

MOTEURS LEROY-SOMER  
Boulevard Marcellin Leroy  
CS 10015  
16915 ANGOULEME Cedex 9  
France

MLS HOLICE SPOL. S R.O.  
Sladkovského 43  
779 00 OLOMOUC  
Czech Republic

MOTEURS LEROY-SOMER  
1, rue de la Burelle  
Boite Postale 1517  
45800 St Jean de Braye  
France

The manufacturer hereby declares that the synchronous alternators of series:


- ✓ Low voltage: LSA 40 – 42.3 – 44.3 – 46.2 – 46.3 – 47.2 – 49.1 – 49.3 – 50.2 – 52.3 – 53.2 – 54.2 – 56 – 58
- ✓ High voltage: LSA 50 – 52.3 – 53 – 53.2 – 54 – 54.2 – 56 – 58 – 60 – 62
- ✓ As well as their deviations

The above declaration is made subject to:

- ✓ Approval by Leroy-Somer regarding the dimensioning of synchronous alternators
- ✓ Recommended use of Leroy-Somer D510C, D550 or D700 AVR

Leroy-Somer Technical Managers

J.P.CHARPENTIER



Y.MESSIN

