

CERTIFICATE OF COMPLIANCE

Certificate Number 20190701-E334232
Report Reference E334232-20190701
Issue Date 2019-JULY-01

Issued to: MOTEURS LEROY SOMER
BLVD MARCELLIN LEROY
16015 ANGOULEME FRANCE

**This certificate confirms that
representative samples of**

CONTROLS FOR STATIONARY ENGINE-DRIVEN
ASSEMBLIES
USL, CNL – Open-Type AVR (Alternator Voltage Regulator)
Model D550

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 6200, OUTLINE OF INVESTIGATION FOR CONTROLS FOR
STATIONARY ENGINE DRIVEN ASSEMBLIES
CSA C22.2 NO. 14-18, INDUSTRIAL CONTROL EQUIPMENT
CSA C22.2 No. 0.2-16, standard for Insulation Coordination

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

